



Petro liyan vision
پترو لیان ویژن

تاریخ نمونه گیری: ۱۴۰۰/۰۹/۲۵

محل نمونه گیری: مخزن B1

Analysis Heavy Hydrocarbon

Row	TEST	METHOD	UNIT	RESULT	
1	Density @15°C	ASTM D1298	Kg/m3	0.793	
2	Distillation, °C	ASTM D86	°C	IBP	142
				10% Volume @°C	163
				20% Volume @°C	171
				30% Volume @°C	179
				40% Volume @°C	188
				50% Volume @°C	200
				60% Volume @°C	211
				70% Volume @°C	226
				80% Volume @°C	242
				90% Volume @°C	268
				95% Volume @°C	286
	FBP	334			
3	Residue	ASTM D86	%vol	1	
4	MERCAPTAN	FTIR Technique	ppm	284	
5	color	ASTM D1500	-	0.8	
6	Sulphur	ASTM D4294	%mass	0.26	
7	Flash point close cup	ASTM D93	°C	46	

Petro liyan vision